

Now that notification devices (visuals) are listed for high and low temperatures, humidity in excess of 85% and Montgomery County enforces the 2002 edition by state law. We are required to enforce these sections, to include open and underground parking areas since the humidity exceeds 85% in the county.

Please check with the other AHJ's in the area for their requirements.

*NFPA 72 (2002 edition)*

*7.3.1 Listing. All notification appliances installed in conformity with Chapter 7 shall be listed for the purpose for which they are used.*

*7.3.3 Physical Construction. Appliances intended for use in special environments, such as outdoors versus indoors, high or low temperatures, high humidity, dusty conditions, and hazardous locations, or where subject to tampering, shall be listed for the intended application.*